



THE DIMMERS CAN BE CONTROLLED VIA CHILLINET PROTOCOL OR DMX 512 PROTOCOL.
PRIORITY OVER WHICH PROTOCOL SHOULD TAKE PRECEDENCE CAN BE SET AT THE DIMMERS

THE FIRE ALARM INTERFACE ON THE CHILLI REQUIRES 0 VOLT NORMALLY OPEN RELAY FROM THE FIRE ALARM WILL BRING ALL CHANNELS TO 80%
THIS STATE CANNOT BE ALTERED UNTIL THE FIRE ALARM IS DEACTIVATED

ITEMS NOT DRAWN TO SCALE